

Trinkwasseranalyse 2022

Schierling – Mannsdorf – Oberlaichling – Unterlaichling



UNSER WASSER
Unser Leben

Parameter	Einheit	Wert
PH-Wert		7,63
Temperatur	°C	11,5
Gesamthärte	°dH	16,7
Härtebereich		3 / hart
Calcium	mg/l	67,4
Magnesium	mg/l	31,7
Nitrat	mg/l	13,7
Natrium	mg/l	4,0
Kalium	mg/l	0,9
Sulfat	mg/l	12,1
Chlorid	mg/l	9,3
Fluorid	mg/l	0,15
Arsen	mg/l	<0,001
Cadmium	mg/l	<0,0003
Amonium	mg/l	<0,01
Eisen	mg/l	<0,005
Mangan	mg/l	<0,005
Aluminium	mg/l	<0,02
Nitrit	mg/l	<0,02
Blei	mg/l	<0,001

Probenentnahme am: 11.07.2022

Analyse durch Labor Dr. Blasy / Dr. Busse, Moosstr. 6a, 82279 Eching a. Ammersee

